

График
нагрузки трансформатор . по ТП

№	№ ТП	Тр-р	Инн	% загруженности тр-ра		% загруженности тр-ра		% загруженности тр-ра					
				10/1	11/1	12/1	13/1	14/1	15/1	16/1	17/1	18/19	
				1	2	3	4	5	6	7	8		
ВЛ-10кВ Ф-7													
1	КТП-90	400	578	36	87	75	92	86	85	86	70	92	
2	КТП-85	250	362	78	79	60	49	62	55	56	56	61	
3	КТП-86	250	362	25	45	45	41	42	35	35	32	31	
4	КТП-89	315	455	56	73	82	75	81	71	51	86	73	
5	КТП-87	250	362	60	45	99	77	82	94	103	87	85	
6	КТП-69	400	578	45	-	57	67	74	56	74	56	64	
7	КТП-73	250	362	30	-	-	30	64	61	44	32	90	
8	КТП-75	160	231	69	84	91	76	78	71	86	76	90	
9	КТП-71	250	362	88	122	82	105	109	117	65	73	40	
10	КТП-72	100	144	22	19	19	40	35	29	50	43	35	
11	КТП-74	160	231	91	115	66	85	87	86	103	89	58	
12	КТП-76	630	910	34	41	39	33	30	30	50	30	0	
		630	910	0	0	0	0		0			36	
13	КТП-65	630	910	1	-	-	93	95	95	81	85	83	
14	КТП-104	160	231	53	78	61	62	67	54	52	64	68	
15	КТП-105	250	362	35	84	74	100	71	85	81	70	60	
16	ТП-63	400	578	29	43	37	46	55	55	48	58	59	
		630											
17	КТПН-78	100	144	78	78	64	56	77	56	58	52	83	
18	КТП-60	250	362	17	-	57	55	60	10	10	16	37	
19	КТП-61	160	231	0	-	-	-0	0	2	2	2	2	
20	КТПН-91	100	144	118	98	61	79	86	78	63		53	
21	КТП-77	250	231	48	90	82	100	93	87	80	72	70	
22	КТП-70	250	362	6	-	-	7	4	7	4	4	4	
23	КТП-80	400	578	44	60	62	32	52	45	48	54	67	
24	КТПН-79	250	362	38	46	50	54	57	37	42	43	40	
25	ТП-88	100	144	-	-	-	65	65	54	56	57	67	
26	ТП-96	100	144	-	-	-	26	53	51	63	65	51	
27	КТП-98	630	910					15	20	20	20	25	
		630	910										
28	КТП-99	160	231									43	